

# Blue Jeans Cable

Network Cable Test Report -- for more details, protocols, etc. see  
[www.bluejeanscable.com/networkcablereports.htm](http://www.bluejeanscable.com/networkcablereports.htm)



## Cable ID: OCV-1C

Date / Time: 07/23/2013 09:55:32 AM

Headroom 2.1 dB (NEXT 36-45)

Test Limit: ISO Patch Cord Cat6A 0.5m

Cable Type: Cat 6A FTP

Operator: BJC

Software Version: 2.7400

Limits Version: 1.9300

NVP: 74.0%

## Test Summary: PASS

Model: DTX-1800

Main S/N: 2300619


Remote S/N: 2300620

Main Adapter: DTX-PC6A/MN ISO/IEC


Remote Adapter: DTX-PC6A/SR ISO/IEC

Wire Map	1	2	3	4	5	6	7	8	S
<b>PASS</b>									
(T568B)	1	2	3	4	5	6	7	8	S

Length (ft)	[Pair 12]	1
Prop. Delay (ns)	[Pair 45]	2
Delay Skew (ns)	[Pair 45]	1
Resistance (ohms)	[Pair 36]	0.3



	Worst Case Margin		Worst Case Value	
<b>PASS</b>	MAIN	SR	MAIN	SR
Worst Pair	36-45	36-78		
<b>NEXT (dB)</b>	2.1	4.2		
Freq. (MHz)	163.0	500.0		
Limit (dB)	43.1	30.9		



<b>PASS</b>	MAIN	SR	MAIN	SR
Worst Pair	78	78		
<b>RL (dB)</b>	1.0	1.1		
Freq. (MHz)	383.0	433.0		
Limit (dB)	11.2	10.4		

